


**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Zavala County Jail

Date:

April 22, 2019

Item	Section	Paragraph	Comments
1	259	.167	<p>Audible Communication. Two-way voice communication shall be available at all times between inmates and jailers, licensed peace officers, bailiffs and staff designated by the sheriff.</p> <p>There is no two-way voice communication between inmates and staff as required by minimum jail standards. The administration failed to add an intercom to the recreation yard as recommended by technical assistance during the FY 2018 annual inspection.</p>
2	263	.55	<p>All life safety equipment shall be inspected, maintained, and tested by persons qualified to do so (whether under vendor contract, by state or private agency or otherwise) in order that such equipment shall be safe, secure, and fully operative at all times.</p> <p>This inspector observed that the fire panel was last inspected on January 10, 2018 which places the inspection 102 day past due.</p>
	279	.3	<p>Preventive maintenance, to include necessary repairs, shall be conducted to ensure a safe, secure, and sanitary facility.</p> <p>While conducting the walk-through of the jail, this inspector observed there to be multiple lights out in the halls and in the inmate living areas including security lights, broken windows and paint chipping in many areas of the jail. This inspector observed the toilet sink combos were leaking in the west cell.</p>



Jennifer Shumake, T.C.J.S. Inspector