

TEXAS COMMISSION ON JAIL STANDARDS

EXECUTIVE DIRECTOR
Brandon S. Wood



P.O. Box 12985
Austin, Texas 78711
Voice: (512) 463-5505
Fax: (512) 463-3185
<http://www.tcjs.state.tx.us>
info@tcjs.state.tx.us

NOTICE OF NON-COMPLIANCE RAINS COUNTY JAIL

March 28, 2023

Please reference the Inspection Requirements Review and Jail Inspection Report issued on March 28, 2023, detailing the specific issues that resulted in the issuance of this notice of non-compliance.

Minimum Standards Violated:	Corrective Measure Required	Date Corrective Action Must Be Completed
263.42	The facility shall be inspected annually by a local fire official who is certified by the Texas Commission on Fire Protection or who meets the alternative criteria provided in Government Code 419.909 and shall pass the inspection. The facility was last inspected by a local fire official in August 2021. This places the annual inspection past due by eight months.	Upon receipt of this notice.
279.1(2)	Water and sewage systems not part of a public system and food preparation areas shall be inspected at least annually by health authorities and record kept for each inspection. The facility was last inspected by health authorities on August 12, 2021. This places the annual inspection past due by eight months.	Upon receipt of this notice.

Judge Bill Stoudt, Longview, Chair
Dr. Esmaeil Porsa, M.D., Parker, Vice-Chair
Ross Reyes, Melissa

Sheriff Kelly Rowe, Lubbock
Sheriff Raul "Pinky" Gonzales, Refugio
Patricia M. Anthony, Garland

Commissioner Ben Perry, Waco
Duane Lock, Southlake
Monica McBride, Alpine

"The Commission on Jail Standards welcomes all suggestions and will promptly respond to all complaints directed against the agency or any facilities under its purview".

To empower local government to provide safe, secure and suitable local jail facilities through proper rules and procedures while promoting innovative programs and ideas